

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28046

1. OWNER Bob Royal ADDRESS AT WELL LOCATION 4835 Angle Silver Springs NV 89429
 MAILING ADDRESS 2825 Tonopah Silver Springs NV 89429
 2. LOCATION SW 1/4 SW 1/4 Sec. 26 T. 18 N. R. 25 E. Lyon County
 PERMIT NO. 18-522-06 Parcel No. _____ Subdivision Name Silver Springs
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Brown clay and sands</u>		<u>20</u>	<u>56</u>	<u>36</u>
<u>Blueish Gray Clay</u>		<u>56</u>	<u>106</u>	<u>50</u>
<u>Coarse Red Gravels and Sands</u>	<u>XX</u>	<u>106</u>	<u>130</u>	<u>24</u>

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/4 Inches To 130 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1/88</u>	<u>0</u>	<u>130</u>

Perforations:
 Type perforation M:115107
 Size perforation 3 x 3/32
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature Cold °F Quality Good

Date started 6-28- 1996
 Date completed 6-29 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>45</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Co. Contractor
 Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1905
 Signed Michael J. Haek
 By driller performing actual drilling on site or contractor
 Date 6-29-96