

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

2nd Well → NOTICE OF INTENT NO. 293510

1. OWNER Smitselaar  
 MAILING ADDRESS \_\_\_\_\_  
 ADDRESS AT WELL LOCATION 11005 Angel E QUINCE  
SILVER SPRING, NV  
 2. LOCATION NW 1/4 SE 1/4 Sec. 31 T. 18 N/S R. 25 E. 01 County \_\_\_\_\_  
 PERMIT NO. 17-051-02  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Misc

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		30	33	
Sand		33	36	
Sand Gravel		36	44	
Clay		44	43	
Gravel		43	61	
Clay		61	106	
Coarse Gravel		106	120	

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>15</u>	<u>2.19</u>	<u>1</u>	<u>120</u>

Perforations:  
 Type perforation Taper Cut  
 Size perforation 3/16 x 6 x 5 round  
 From 112 feet to 117 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

Date started 10/13/96, 19\_\_\_\_  
 Date completed 10/17/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80-85</u>	<u>4 1/2</u>	

9. WATER LEVEL  
 Static water level 28' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Gene Drilling Inc Contractor  
 Address 20 599 Contractor  
S.S. NV 89422  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1874  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/13/96