WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65038
Permit No.
Basin 101

NOTICE OF INTENT NO. 34388

1. OWNER Ken Reidinger
MAILING ADDRESS 4580 Silver Sage Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION
4580 Silver Sage Lane, Fallon, NV 89406

2. LOCATION SW 1/4 SW 1/4 Sec. 18 T 18N N/S R 29E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 006-811-76 Parcel No. | _____ Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sand		0	5	5
Brown Clay		5	12	7
Coarse Brown Sand		12	19	7
Brown Clay		19	23	4
Brown Sand	X	23	28	5
Brown Clay		28	29	1

Date started 8/20/96, 19__
Date completed 8/20/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	29	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	29

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 25 feet to 29 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 25
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 29 feet

9. WATER LEVEL
Static water level 6.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons
By driller performing actual drilling on-site or contractor

Date 8/21/96