

OFFICE USE ONLY  
 Log No. 63094  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 8820

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Betty Hollis ADDRESS AT WELL LOCATION TRENE ST.  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec. 5 T. 20 S N/S R. 53 E Nye County  
 PERMIT NO. N/A 36-031-15 Parcel No. Lot-3 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0'	19'	19'
Caliche		19'	21'	2'
CLAY		21'	38'	17'
Caliche		38'	42'	4'
CLAY		42'	54'	12'
Caliche	WB	54'	57'	3'
CLAY		57'	68'	11'
Caliche	WB	68'	71'	3'
CLAY		71'	89'	18'
Caliche	WB	89'	92'	3'
CLAY		92'	118'	26'
Caliche	WB	118'	121'	3'
CLAY		121'	131'	10'
Caliche	WB	131'	134'	3'
CLAY		134'	140'	6'

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' X 8 5/8"  
 Weight per foot 14.11 Thickness .156  
 Diameter 8 5/8 inches From 0' feet To 140' feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140' feet to 50' feet  
 Perforations:  
 Type perforation FACTORY SAWCUT  
 Size perforation 1/8" X 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 JAN 14 1991

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 12-27, 1990  
 Date completed 1-4, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HR 65 Box 80358 Pahrump, NV 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donna Brown  
 By driller performing actual drilling on site or contractor  
 Date 1-11-91