



Log No. 63097  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER William Knudsen ADDRESS Las Vegas Nev  
 2. LOCATION NE 1/4 NW 1/4 Sec. 5 T. 20 N/S R. 33 E. Nye County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
surface		0	3	3
Brown clay		3	36	33
soft brown clay	X	36	65	29
hard brown clay		45	48	3
soft brown clay	X	48	140	72

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 140 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 13 1/2 lbs Thickness 10 gauge  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation touch cut  
 Size perforation 3/4" wide 8" long  
 From 60 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 JUL 10 1978

Div. of Water Resources  
 Branch Office - Las Vegas, Nev.

Date started June 20, 1978  
 Date completed June 25, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 gal Draw down 0 feet 0 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 33 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cool F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Well Drilling  
 Address Box 5231 Primm Nev  
 Nevada contractor's license number 7484  
 Nevada driller's license number 225  
 Signed Charles Nyberg  
 Date 7-15-78