WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63110
Permit No.
Basin

NOTICE OF INTENT NO. 3723

PRINT OR TYPE ONLY

1. OWNER Bob Weiss
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 5 T. 20 S N/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) Lot 12 (Parcel No.) Pechstein Ranch (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	10	10 ft
CALICHIE		10	12	2 ft
CLAY		12	32	20 ft
CALICHIE		32	33	1 ft
CLAY		33	58	25 ft
CALICHIE	TR	58	59	1 ft
CLAY		59	70	11 ft
CALICHIE	WB	70	71	1 ft
CLAY		71	79	8 ft
CALICHIE	WB	79	80	1 ft
CLAY		80	84	4 ft
CALICHIE	WB	84	85	1 ft
CLAY		85	110	25 ft
CALICHIE	WB	110	111	1 ft
CLAY		111	122	11 ft
CALICHIE	WB	122	123	1 ft
CLAY		123	130	7 ft
CALICHIE	WB	130	134	4 ft
CLAY		134	140	6 ft

RECEIVED
NOV 22 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-10, 1989
Date completed 11-15, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140 ft 8 5/8
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Factory Sawcut
Size perforation ⅛th x 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 49 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H. Drilling (Contractor)
Address HCR 65 Box 70906 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dennis Brown (By driller performing actual drilling on site or contractor)
Date 11-20-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627