WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63126
Permit No.
Basin 162

NOTICE OF INTENT NO. 13193

1. OWNER Bud Duskin
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 9 T 20-S N/S R 53 E Nye County
PERMIT NO. APN 35-162-01 (Issued by Water Resources) | 279 Unit D (Parcel No.) | Cal-Vegas Acres (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	26	22
Light Brown Clay		26	48	22
Hard Strip		48	52	4
Soft Brown Clay	x	52	78	16
Light Brown Clay		78	101	23
Hard Strip		101	116	15
Soft Brown Clay	x	116	121	5
Hard Strip		121	132	11
Soft Brown Clay	x	132	140	8

DCNR/DWR Received FEB 21 1996 LAS VEGAS OFFICE

Date started February 5, 1996
Date completed February 6, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18 lbs.	.188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Clark Nyberg (By driller performing actual drilling on site or contractor)
Date February 12, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627