WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63136
Permit No.
Basin 162

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1901

OWNER Jansen
MAILING ADDRESS Pahrump, Nev. 89041

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 9 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Lot No. 93 (Parcel No.) Unit D Cal-Vegas Ranchos (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Soft Brown Clay | | 4 | 40 | 36 |
| Tough Brown Clay | | 40 | 48 | 8 |
| Soft Brown Clay | x | 48 | 80 | 32 |
| Chalky White Clay | x | 80 | 115 | 35 |
| Brown Clay | x | 115 | 140 | 25 |

RECEIVED
DEC 27 1984
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started December 15, 19 84
Date completed December 15, 19 84

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 gals. Draw down 4 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 140 ft. of 8 in casing
Weight per foot 15 lbs. Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Torch Cut
Size perforation 3/8 in width 8 in long
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address ST.RT.BOX 36525 (Contractor)
Nevada contractor's license number 7484
Nevada contractor's drillers number
Nevada driller's license number 725 (Actual Driller)
Signed Charles Nyberg (Contractor)
Date 12/26/84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434