WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63149
Permit No.
Basin

1. OWNER JACK DICKMAN ADDRESS PAHRUMP NEVADA

2. LOCATION SE ¼ NE ¼ Sec. 6 T. 20 N/S R. 53 E. NYE County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☒ Irrigation ☐ Test ☐	Cable ☒ Rotary ☐
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	5	5
SOFT BROWN CLAY		5	26	21
SOFT SANDY CLAY		26	60	34
BROWN CLAY		60	120	60

RECEIVED
MAR 7 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 2-17, 19 79
Date completed 2-23, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 120 feet
Casing record 120
Weight per foot 13 LBS Thickness 10 GAUGE

Diameter	From	To
8 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" WIDE 8" LONG
From 60 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL

Static water level 30 Feet below land surface
Flow ____ G.P.M.
Water temperature ____ ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES NYBERG WELL DRILLING
Address STAR ROUTE BOX 5231 PAHRUMP
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 2-28-78

USE ADDITIONAL SHEETS IF NECESSARY

5471