


Log No. 63197

Permit No. \_\_\_\_\_  
 Basin 162



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2517

INT OR TYPE ONLY

OWNER Tom Worburton Sr. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec 10 T 20S N/S R 53 E Nye County \_\_\_\_\_

PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	38	38
Caliche		38	41	
Clay		41	50	
Caliche		50	53	
Clay		53	80	
Caliche		80	84	
Clay		84	92	
Caliche		92	100	
Clay		100	112	
Caliche		112	124	
Clay		124	135	
Caliche		135	140	
Clay		140	156	
Caliche		156	160	
Clay		160	170	
Caliche		170	185	
Clay		185	195	
Gravel		195	200	

RECEIVED  
 SEP 21 1989

Date started 12-5 1988  
 Date completed 12-6 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 200 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 200 ft 8 5/8 inch  
 Weight per foot 14.11 Thickness 156  
 Diameter 8 5/8 inches From 0 feet To 200 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 200 feet  
 Perforations:  
 Type perforation SAW  
 Size perforation 1/8 inch by 3 inch  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 54 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 100.1 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S&H Drilling Contractor  
 Address HCR 65 Box 70906 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-30-89