



Log No. 63206
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

OWNER Don & Sharon Maxwell ADDRESS Pahrump Nev

2. LOCATION NE 1/4 SE 1/4 Sec 6 T. 20 N/S R. 53 E Nye County

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	5. TYPE WELL Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Other <input type="checkbox"/>
--	--	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>surface</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>white clay</u>		<u>3</u>	<u>16</u>	<u>13</u>
<u>soft brown clay</u>	<input checked="" type="checkbox"/>	<u>14</u>	<u>34</u>	<u>40</u>
<u>Brown clay</u>		<u>56</u>	<u>76</u>	<u>20</u>
<u>soft brown clay</u>	<input checked="" type="checkbox"/>	<u>76</u>	<u>120</u>	<u>44</u>

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 120 feet
 Casing record 120 ft
 Weight per foot 13 1/2 lbs Thickness 10 gauge

Diameter	From	To
<u>8</u> inches	<u>0</u>	<u>120</u> feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet

Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation tand cut
 Size perforation 3/8" wide 8" long
 From 60 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED
 JUL 18 1978
 Div. of Water Resources
 Branch Office — Las Vegas, Nev.

Date started June 5, 1978
 Date completed June 6, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. <u>20 gal</u>	Draw down <u>0</u> feet	<u>0</u> hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 28 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cool ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling
 Address Box 5231 Pahrump Nev
 Nevada contractor's license number 7484
 Nevada driller's license number 725
 Signed Charles Nyberg
 Date 7-15-78