WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 63225
Permit No.
Basin

In Book

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Richard Morrison ADDRESS 5900 W. Tropp. #38 Las Vegas, NV 89103

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 20 N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
soft brownclay		4	14	10
brown clay		14	44	30
soft brown clay	x	44	110	66
brown clay		110	122	12
soft brown clay	x	122	140	18

RECEIVED
DEC 10 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 12-3, 1979
Date completed 12-3, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 8" casing 140' deep
Weight per foot 13⅓ lbs Thickness 10GA

Diameter	From	To
8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8" x 8"
From 60 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 29 Feet below land surface 28
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address Star Rt. 5231 Pahrump, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 12-5-79

USE ADDITIONAL SHEETS IF NECESSARY

5471