DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 632347
Permit No.
Basin 162

1. OWNER STANLEY BIEDERMAN ADDRESS PAHRUMP

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 20 N/S R. 53 E. NYE County
PERMIT NO. DOMESTIC

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	6"	6"
HARD CLAY		6"	3'	2½'
RED LOOSE CLAY		3'	4'	1'
BROWN CLAY		4'	10'	6'
SANDY CLAY + CALIC		10'	16'	6'
SAND STONE + CLAY		16'	21'	5'
SAND	X	21'	22	1'
SANDY CLAY		22'	24'	2'
RED SANDY CLAY	X	24'	30'	6'
SAND STONE		30'	33'	3'
SANDY CLAY		33'	37'	4'
SAND	X	37'	39'	2'
SAND STONE + CLAY		39'	63'	24'
SANDY CLAY		63'	66'	3'
SAND STONE		66'	70'	4'
SAND	X	70'	71'	1'
SANDY CLAY		71'	75'	4'
CALICHE		75'	82'	7'
LIME STONE		82'	84'	2'
CALICHE + CLAY		84'	90'	6'
CLAY + SAND		90'	94'	4'
CLAY + CALICHE		94'	98'	4'
SAND		98'	106'	8'
SANDY CLAY		106'	129'	23'
CALICHE + CLAY		129'	142'	13'
SANDY CLAY		142'	158'	16'
CALICHE		158'	160'	2'

Date started 7-8-, 19 74
Date completed 7-16-, 19 74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
NOV 25 1974
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record
Weight per foot 12.75 Thickness 10.2

Diameter	From	To
8-5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 65' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 65 feet to 160 feet

Perforations:
Type perforation TORCH CUT
Size perforation ¼" x 12" 2 ROWS
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31 Feet below land surface 31
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne L. Floyd
Address P.O. Box 32 A.
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 10-30-74

USE ADDITIONAL SHEETS IF NECESSARY

5471