

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 32536

Consultant: _____ Client: _____
 1. OWNER CDM Engineers & Constructors Inc ADDRESS AT WELL LOCATION Santa Fe Pipeline
 MAILING ADDRESS 50 W Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION NE 1/4 NE 1/4 Sec. 9 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. M/O 913 A-1 34-102-14 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown fine grained silty sand w/subround gravel, lose, dry		0	8	8
Brown subround to sub-granular sand w/subround to angular gravel, abundant cobbles and minor silt, med dence		8	30	22
Color change to gray brown below 15 feet				
Gray brown sand w/gravel abundant cobbles, minor silt, med dence		30	60	30
Color change to lt brown below 40 feet				
Light brown sand w/gravel abundant cobbles, minor silt, med dence		60	89.2	28.2
Little or no silt below 85 feet				

8. WELL CONSTRUCTION
 Depth Drilled 89.2 Feet Depth Cased 89 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/4 Inches 0 Feet 89.2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/ cap	sch 80 PVC	0	27.5
6"		SS sump w/cap	83.6	89.
Centralizers		83,63,42,27	SS	

 Perforations: factory sawed slot
 Type perforation _____
 Size perforation .100 slot SS wire wrapped
 From 27.5 feet to 83.6 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 22.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 22.5 - 24.5
 Gravel Packed: Yes No 1/4-1/8" well sand
 Filter 24.5-25.5 #20 feet to 25.5-89 feet

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By Driller performing equal drilling on site or contractor
 Date January 30, 1996

Date started 05-15-95, 19_____
 Date completed 05-17-95, 19_____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			