

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32537

Consultant: CDM Engineers & Constructors Inc Client: \_\_\_\_\_  
1. OWNER: \_\_\_\_\_ ADDRESS AT WELL LOCATION Santa Fe Pipeline  
MAILING ADDRESS 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site  
Reno, Nevada 89501 Sparks, Nevada  
2. LOCATION SE 1/4 NE 1/4 Sec 9 T 19N N/S R 20 E Washoe County  
PERMIT NO. M/O 913 B-1 34-102-14 Sparks Solvent Fuel Site  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown silt w/ sand, med. dense, dry		0	9	9
Lt. brown subangular to subround sand w/ angular to subround gravel, abundant cobbles and minor silt, med. dense		9	30	21
Lt. brown sand w/ gravel abundant cobbles and minor silt, med. dense.		30	60	30
Color change to gray brown below 40ft				
Color change to lt. brown below 45ft.				
Lt. brown sand w/ gravel abundant cobbles and minor silt, med. dense, saturated		60	79.2	19.2

8. WELL CONSTRUCTION  
Depth Drilled 79.2 Feet Depth Cased 77 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
11 1/4" Inches 0 Feet 79.2 Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6" w/cap SCH 80 PVC 0 30.9  
6" SS sump w/cap 71.4 77  
Centralizers 71,50,29 SS  
Perforations:  
Type perforation factory sawed slot  
Size perforation .100 slot SS wire wrapped  
From 30.9 feet to 71.4 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 3 - 25.9  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Bentonite Seal:  25.9 - 27.9 1/4-1/8" well sand  
Gravel Packed:  Yes  No  
Filters 27.9 - 28.9 #20 feet to 28.9 - 79.2 feet

Date started 5-22-95, 19\_\_\_\_\_  
Date completed 5-23-95, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
no test			

9. WATER LEVEL  
Static water level not known feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. N/A P.S.I.  
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WAYNE DRILLING, INC.  
Contractor  
Address P.O. Box 12370  
Contractor  
Reno, Nevada 89510  
Nevada contractor's license number issued by the State Contractor's Board 22549  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date January 31, 1996