

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32540

Consultant: CDM Engineers & Constructors Inc. Client: _____
 1. OWNER: _____ ADDRESS AT WELL LOCATION: Santa Fe Pipeline
 MAILING ADDRESS: 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION: NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 9 T. 19N N/S R. 20 E. Washoe County
 PERMIT NO. M/O 913 C-1 34-102-13 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other: TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown silty sand w/ minor clay, scattered gravel med. dense, moist		0	14	14
Lt. brown sand w/ silt and subangular to subround gravel abundant cobbles, trace of silt		14	30	16
color change to gray brown and minor silt below 22ft.				
Gray brown sand w/ gravel abundant cobbles and minor silt, med. dense		30	60	30
Saturated below 38 ft. color change to lt. brown below 40ft.				
Lt. brown sand w/ gravel abundant cobbles, minor silt med. dense, saturated		60	66	6

8. WELL CONSTRUCTION
 Depth Drilled 68.5 Feet Depth Cased 66 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/2" Inches 0 Feet 68.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	Sch 80 PVC	0	24.6
6"		SS Sump w/cap	60.6	66

 Centralizers 60,42,23 SS
 Perforations:
 Type perforation factory sawed slot
 Size perforation .100 slot SS wire wrapped
 From 24.6 feet to 60.6 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 19.6 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 19.6 - 21.6
 Gravel Packed: Yes No 1/4-1/8 well sand
 Filter From 21.6 - 22.6 #20 feet to 22.6 - 68.5 feet

Date started 5-26-95 19_____
 Date completed 5-31-95 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 31, 1996