

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32544

Consultant: 1. OWNER CDM Engineers & Constructors Client: AT WELL LOCATION Santa Fe Pipeline
 MAILING ADDRESS 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION NW 1/4 NE 1/4 Sec. 9 T. 19N N/S R. 20 E. Washoe County
 PERMIT NO. M/O 913 D-1 34-102-15 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand, loose, dry		0	15	15
Color change to gray-brown, slightly moist below 3ft.				
Color change to lt. gray				
Gray brown subangular to subround sand w/ angular to subround gravel, abundant cobbles, minor silt, med. dense.		15	30	15
Color change to lt. gray below 24ft.				
Color change to lt. brown, saturated below 29ft.				
Brown sand w/ gravel, abundant cobble, minor silt, med dense, saturated		30	63.75	33.75
Color change to lt. red-brown below 50ft.				

8. WELL CONSTRUCTION
 Depth Drilled 63.8 Feet Depth Cased 63.8 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/2 Inches 0 Feet 63.8 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	17.5
6"		SS Sump w/cap	58.4	63.8
Centalizers		58.38, 18 SS		

Perforations:
 Type perforation Factory sawed slot
 Size perforation .100 slot SS wire wrapped
 From 17.5 feet to 58.4 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 11.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 11.5 - 13.5
 Gravel Packed: Yes No 1/4-1/8" well sand
 Filter From 13.5 - 15.5 #20 feet to 15.5 - 63.8 feet

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

Date started 8-24-95, 19_____
 Date completed 8-25-95, 19_____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 5, 1996