WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63336
Permit No.
Basin

1. OWNER Herb Kladt ADDRESS
Lot 12 Block C Landmark Subdivision
2. LOCATION ¼ ¼ Sec. 16 T. 20 S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
Brown Clay		6	28	22
Red Clay		28	45	17
Gray Clay		45	100	55
Brown Clay w/streaks of granulated Clay		100	160	60

RECEIVED
FEB 3 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 1-29-, 19 82
Date completed 1-30, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole ~~160~~ 12¼ inches Total depth 160' feet
Casing record 8 5/8
Weight per foot 14.53 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cmt
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 6 3 Rows
From 80 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface 40
Flow G.P.M.
Water temperature Cool ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin Drilling Inc
Address 4425 Stacey Ave
Nevada contractor's license number C16521
Nevada driller's license number 1081
Signed [illegible]
Date 1-30-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627