WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63345
Permit No.
Basin 087

NOTICE OF INTENT NO. 27274

Consultant:
1. ~~OWNER~~ CDM Engineers & Constructors Inc.
MAILING ADDRESS 50 W. Liberty, Suite 770
Reno, Nevada 89501

Client: Santa Fe Pipeline
ADDRESS AT WELL LOCATION Vista Canyon Group Sparks Solvent/Fuel Site
Sparks, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 9 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O 913 D-2 (Issued by Water Resources) | 34-102-15 (Parcel No.) | Sparks Solvent/Fuel Site (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand, loose, moist		0	2	2
Brown clay w/sand, soft, moist		2	5	3
Gray subangular to subround sand w/ subround to angular gravel, abundant cobbles med. dense		5	30	25
Encountered boulder from 20 to 25ft.				
Color change to lt. brown below 30ft.				
Lt. brown sand w/ gravel abundant cobbles, med. dense		30	64.9	34.9
Color change to lt. red brown below 50ft.				

Date started 8-28-95, 19
Date completed 8-29-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

8. WELL CONSTRUCTION
Depth Drilled 64.9 Feet Depth Cased 63.6 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½" Inches		0 Feet	64.9 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	17
6"		SS Sump w/cap	58.2	63.6
Centralizers		58,38,16.5	SS	

Perforations:
Type perforation Factory sawed slot
Size perforation .100 SS wire wrapped
From 17. feet to 58.2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 - 11.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 11 - 13
Gravel Packed: ☒ Yes ☐ No 1/4-1/8" well sand
Filter
From 13 - 15 #20 feet to 15.- 64.9 feet

9. WATER LEVEL
Static water level not known feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date February 5, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627