WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63364
Permit No.
Basin 087

NOTICE OF INTENT NO. 32539

1. ~~OWNER~~ Consultant: CDM Engineers & Constructors Inc.
MAILING ADDRESS 50 W. Liberty, Suite 770
Reno, Nevada 89501

Client: Santa Fe Pipeline
ADDRESS AT WELL LOCATION Vista Canyon Group Sparks Solvent/Fuel Site
Sparks, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 9 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O 913 F-3 (Issued by Water Resources) | 34-101-37 (Parcel No.) | Sparks Solvent/Fuel Site (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown subangular to subround				
sand w/ angular to subround				
gravel, abundantcobbles and				
minor silt, med. dense dry.		0	30	30
Color change to brown gray				
and abundant clay below 5ft.				
No clay below 7ft.				
Color change to lt. gray				
below 10ft.				
Color change to gray brown				
below 14 ft.				
Gray brown sandw/ gravel,				
abundant cobbles, minor				
silt, med. dense.		30	59.5	29.5
Color change to lt. brown				
and saturated below 35ft.				

Date started 8-7-95, 19
Date completed 8-8-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

8. WELL CONSTRUCTION
Depth Drilled 59.5 Feet Depth Cased 59.1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	59.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	18.3
6"		SS Sump w/cap	53.7	59.1
Centralizers		53,35,17 SS		

Perforations:
Type perforation Factory sawed slot
Size perforation .100 slot SS wire wrapped
From 18.3 feet to 53.7 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 - 13.3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 13.3 - 15.3
Gravel Packed: ☒ Yes ☐ No 1/4-1/8" well sand
Filter From 15.3 - 16.3#20 feet to 16.3 - 59.4 feet

9. WATER LEVEL
Static water level not known feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date February 6, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627