

OFFICE USE ONLY
 Log No. 63971
 Permit No. 087
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27270

Consultant: _____ Client: _____
 1. OWNER CDM Engineers & Constructors Inc ADDRESS AT WELL LOCATION Santa Fe Pipeline
 MAILING ADDRESS 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION NE 1/4 NW 1/4 Sec. 9 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. M/O 913 H-1 32-220-62 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary PVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray subangular to subround sand, med. dense, moist		0	30	30
Angular to subround gravel scattered cobbles and minor silt below 5ft.				
Color change to lt. brown and saturated below 25ft.				
Lt. brown sand w/gravel abundant cobbles and minor silt, med. dense, saturated		30	58	28
Heaving sands filled casing to 54.2				

8. WELL CONSTRUCTION
 Depth Drilled 58 Feet Depth Cased 56 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 58 Feet
11 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	14.6
6"		SS Sump w/cap	50.6	56.
Centralizers		50, 32, 14 SS		

Perforations:
 Type perforation Factory sawed slot
 Size perforation 100 slot SS wire wrapped
 From 14.6 feet to 50.6 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 10.6
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 10.6 - 12.6
 Gravel Packed: Yes No 1/4-1/8" well sand
 Filter 12.6 - 13.6 #20 feet to 13.6 - 58. feet

9. WATER LEVEL
 Static water level NOT KNOWN feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 7, 1996

Date started 4-14-95, 19_____
 Date completed 4-17-95, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
no test			