

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27267

Consultant: CDM Engineers & Constructors Inc Client: _____
 1. OWNER ADDRESS AT WELL LOCATION Santa Fe Pipeline
 MAILING ADDRESS 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION NE 1/4 NW 1/4 Sec. 9 T. 19N N/S R. 20 E. Washoe County
 PERMIT NO. M/O 913 I-1 32-220-62 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown subangular to sub-round sand w/angular to sub-round gravel, abundant cobbles and silt, med. dense, moist		0	30	30
Color change to lt. gray below 6ft.				
Minor amount of silt below 15ft.				
Color change to lt. brown saturated below 24ft.				
Lt. brown sand w/gravel abundant cobbles, minor silt, med. dense, saturated		30	54	24

8. WELL CONSTRUCTION
 Depth Drilled 54 Feet Depth Cased 52 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/4 Inches To 0 Feet 54 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	15.9
6"		SS Sump w/cap	46.6	52
Centralizers		46, 31, 16	SS	

Perforations:
 Type perforation Factory sawed slot
 Size perforation 100 slot SS wire wrapped
 From 15.9 feet to 46.6 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 11.9 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 11.9-13.9
 Gravel Packed: Yes No 1/4-1/8" well sand
 Filter From 13.9-14.9 #20 feet to 14.9-54 feet

Date started 4-19-95, 19____
 Date completed 4-20-95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test		

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 7, 1996