

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 63380
 Permit No. _____
 Basin. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32541

Consultant: _____ Client: _____
 1. OWNER: CDM Engineers & Constructors Inc. ADDRESS AT WELL LOCATION: Santa Fe Pipeline
 MAILING ADDRESS: 50 W. Liberty, Suite 770 Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION: NE 1/4 NW 1/4 Sec. 9 T. 19N N/S R. 20 E. Washoe County
 PERMIT NO. M/O 913 I-1 32-220-62 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lt. brown subangular to sub round sand w/angular to sub round gravel, med. dense, dry.		0	30	30
Color change to gray-brown abundant cobbles below 5ft.				
Color change to lt. gray below 10ft.				
Color change to gray-brown saturated below 25ft.				
Gray-brown sand w/gravel, abundant cobbles, med. dense saturated.		30	49.6	19.6
Color change to lt. brown below 35ft.				

8. WELL CONSTRUCTION
 Depth Drilled 49.6 Feet Depth Cased 49.6 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/2 Inches 0 Feet 49.6 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	13.5
6"		SS Sump w/cap	44.2	49.6
Centralizers		44,29,13 SS		

 Perforations:
 Type perforation Factory sawed slot
 Size perforation .100 slot SS wire wrapped
 From 13.5 feet to 44.2 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 9.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 9.5 - 11.5
 Gravel Packed: Yes No 1/4-1/8" Well sand
 Filter 11.5 - 12.5 #20 feet to 12.5 - 49.6 feet

Date started 6-5-95 19_____
 Date completed 6-6-95 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
no test			

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] driller performing actual drilling on site or contractor
 Date February 13, 1996