

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Page 1 of 2 pages
 NOTICE OF INTENT NO. 32571

Consultant: CDM Engineers & Constructors Inc. Client: Santa Fe Pipeline
 MAILING ADDRESS: 50 W. Liberty, Suite 770 ADDRESS AT WELL LOCATION: Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89501 Sparks, Nevada
 2. LOCATION NW 1/4 NW 1/4 Sec. 10 T. 19N N/S R. 20 E. Washoe County
 PERMIT NO. M/O 913-B P-3 37-030-09 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
No log recorded		0	20	
Brown sand and gravel		20	55	
Moist, med. dense, brown c f sand and c f gravel, trace silt		55	58	3
Moist, med. dense, brown, c f sand and c f gravel, trace silt.		58	60.7	2.7
Moist, med. dense, brown-gray mottled, mf sand, little silt, trace gravel.		60.7	62	2.7
Moist, med. dense, brown-gray mottled, c m f sand, trace gravel and silt.		62	64.5	2.5
Saturated, med. dense, brown mottles, m f sand, little silt.		64.5	65.5	1
Saturated, loose, gray mottled, cmf sand.		65.5	66.1	6
Saturated, med. dense, gray c m f sand, trace gravel and cobbles		66.1	67.	9.
Saturated, med. dense, dark gray, c m f sand and c m f gravel.		67.	68.	1
Saturated, med. dense, gray c m f sand and c f gravel, color change to red brown		68	69.5	1.5
below 69ft. <u>10-16-95</u> (continued page 2)				
Date started <u>10-18-95</u>				
Date completed <u>19</u>				

8. WELL CONSTRUCTION
 Depth Drilled 79 Feet Depth Cased 79 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/2 Inches To 0 Feet 79 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	54
6"		SS Sump w/cap	74	79
SS Centralizers <u>54, 64, 74</u>				

Perforations:
 Type perforation Factory sawed slot
 Size perforation .100 slot SS wire wrapped
 From 54 feet to 74 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 48 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 48 - 50
 Gravel Packed: Yes No 1/2-1/8" Well Sand
 Filter 50 - 52 #20 feet to 52 - 79 feet

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By Driller performing actual drilling on site or contractor
 Date February 20, 1996

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

