WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63384
Permit No.
Basin 087

NOTICE OF INTENT NO. 32571

Consultant:
1. ~~OWNER~~ CDM Engineers & Constructors Inc
MAILING ADDRESS 50 W. Liberty, Suite 770
Reno, Nevada 89501

Client:
ADDRESS AT WELL LOCATION Santa Fe Pipeline
Vista Canyon Group Sparks Solvent/Fuel Site
Sparks, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 10 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O 913 - B P-4 (Issued by Water Resources) 37-030-09 (Parcel No.) Sparks Solvent/Fuel Site (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dry, loose, brown silt, some cobbles and gravel		0	11	11
Slightly moist, med. dense, brown, cf subrounded to sub-angular sand and subrounded cf silt.		11	25	34
Moist, loose, brown, cmf sand, some cobbles and cf gravel.		25	27	2
Med dense, brown sand, some cobbles, little silt below 28ft.		27	55	28
Wet loose, brown, cm sand, some cobbles and cf gravel.		55	58.5	3.5
Wet, loose, brown, cf sand little cobbles and cf gravel, trace silt, clay and silt lens -2 in @59ft.		58.5	60.7	2.2
Wet, loose, brown, cmf sand some cobbles and cf gravel, trace silt.		60.7	70.	9.3

Date started 10-7-95, 19
Date completed 10-9-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

8. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 68 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½ Inches		0 Feet	70 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	43
6"		SS Sump w/cap	63	68
SS Centralizers		43, 53, 63		

Perforations:
Type perforation Factory sawed slot
Size perforation .100 slot SS wire wrapped
From 43 feet to 63 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 - 36.6
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 36.6 - 38.5
Gravel Packed: ☒ Yes ☐ No ¼-1/8" Well Sand Filter
From 38.5-40.6 #20 feet to 40.6-70. feet

9. WATER LEVEL
Static water level not known feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed Gary L. Hedman (By driller performing actual drilling on site or contractor)
Date February 20, 1996

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627