

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32538

1. Consultant: CDM Engineers & Constructors Inc. Client Sant Fe Pipeline  
 OWNER: \_\_\_\_\_ ADDRESS AT WELL LOCATION Vista Canyon Group Sparks Solvent/ Fuel Site  
 MAILING ADDRESS 50 W. Liberty, Suite 770 Reno, Nevada 89501 Sparks, Nevada  
 2. LOCATION SW 1/4 NW 1/4 Sec 10 T 19N N/S R 20 E Washoe County  
 PERMIT NO. M/O 913 A-4 NE of 32-312-04 Nugget Ave. R/W Sparks Solvent/Fuel Site  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray subangular to sub-round sand w/ angular to subround gravel. Abundant cobbles, minor clay, med. dense		0	30	30
Gray sand w/ gravel, abundant cobbles, minor clay, med dense		30	60	30
color change lt. brown minor silt, little or no clay, below 35ft.				
color changed to gray brown and saturated below 55ft.				
color changed to lt. brown below 58ft.				
lt. brown sand w/ gravel abundant cobbles, minor silt, med. dense saturated		60	89.5	29.5

8. WELL CONSTRUCTION  
 Depth Drilled 89.5 Feet Depth Cased 89.3 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 1/2 Inches 0 Feet 89.5 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	sch 80 PVC	0	38
6"		SS sump w/cap	83.9	89.3
centralizers 83,60,38 SS				

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 100 slot SS wire wrapped  
 From 38 feet to 83.9 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3 - 33  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentonite Seal: 33 - 35  
 Gravel Packed:  Yes  No 1/4-1/8" well sand  
 Filter 35 - 36 #20 feet to 36-89.3 feet

Date started 6-7-95 19\_\_\_\_  
 Date completed 6-8-95 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test			

9. WATER LEVEL  
 Static water level not known feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING INC. Contractor  
 Address P.O. Box 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date January 31, 1995