WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63404
Permit No.
Basin 087

NOTICE OF INTENT NO. 30505

1. OWNER Packer Way Service Ctr.
MAILING ADDRESS Sparks, Nv.
ADDRESS AT WELL LOCATION 810 - 990 Meredith Way, Sparks, Nv.

2. LOCATION NE ¼ SW ¼ Sec. 10 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. OCD m/o #712 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
On 1/11/96	17.5			
I found the well				
to be in good				
condition. After				
removing the				
man hole cover				
I then drilled				
the casing out				
to 25'. I followed				
by pressure grouting				
with neat cement				
from 25' to surface				

Date started 1/11, 19 96
Date completed 1/11, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 25' Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0' Feet	25' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N/A			

Perforations:
Type perforation
Size perforation
From N/A feet to N/A feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 25
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 17.5 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford Rd. (Contractor)
Reno, Nv. 89509
Nevada contractor's license number issued by the State Contractor's Board 30525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 2/9/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627