WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

0612

In Book

OFFICE USE ONLY
Log No. 63405
Permit No.
Basin 162

1. OWNER John Sturgeon ADDRESS

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 20 S N/S R. 53 E County
PERMIT NO. Omission

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| tan, grey clay | | 0 | 15 | 15 |
| gr. tan, grey clay | | 15 | 30 | 15 |
| tan, green clay w/cali | | 30 | 45 | 15 |
| grey, white clay w/cali | | 45 | 60 | 15 |
| tan, grey clay w/cali | | 60 | 75 | 15 |
| tan clay w/cali | | 75 | 90 | 15 |
| tan clay w/cali | | 90 | 105 | 15 |
| tan clay w/cali | | 105 | 120 | 15 |
| tan clay w/cali | | 120 | 140 | 20 |
| tan clay w/cali | | 140 | 160 | 20 |

RECEIVED
JUN 14 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started May 22, 1982
Date completed May 25, 1982

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record 8 5/8
Weight per foot ..... Thickness .188

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | 160 feet | 0 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 160 feet to 50 feet

Perforations:
Type perforation torch
Size perforation ¼" by 12"
From 160 feet to 80 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 41' Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name J. W. Floyd
Address P.O. Box 292
Nevada contractor's license number 19268
Nevada driller's license number 588
Signed J. W. Floyd
Date 6/2/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627