


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 63428
Permit No. 61778
Basin 083

NOTICE OF INTENT NO 32432



1. OWNER Asamera Minerals
MAILING ADDRESS 1000 Bible Way Ste. 16
Reno, Nevada

ADDRESS AT WELL LOCATION

2. Location NW 1/4 SE 1/4 Sec 33 T 19N R 22E
PERMIT NO. 61778 W-454 PARCEL NO. 04-090-21

SUBDIVISION NAME

Storey County

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	Domestic	Irrigation	<input checked="" type="checkbox"/> Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Tan, brown, white fine sands.		0	37	37
Brown, red, yellow sands \ red clay.		37	68	31
Light green, dark green, red sands & gravel \ red clay stringers.	95	68	116	48
Red brown yellow volcanic rock \ reddish brown clay.		116	338	222

8. WELL CONSTRUCTION				
Depth Drilled		Depth Cased		
338 feet		338 feet		
HOLE DIAMETER (BIT SIZE)				
12 3/4 inches		0 feet 338 feet		
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	188	+2	338
Perforations:				
Type Perforation	factory			
Size perforation	1/8 x 3" single & double			
From	300 feet to	280 S	feet	
From	260 feet to	250 S	feet	
From	240 feet to	220 S	feet	
From	210 feet to	120 D	feet	
From	feet to feet			
Surface Seal		<input checked="" type="checkbox"/> YES	No	Seal Type:
Depth of Seal		100 feet		<input checked="" type="checkbox"/> Neat Cement
		<input checked="" type="checkbox"/> Pumped		Cement Grout
		Poured		Concrete Grout
Gravel Packed:		<input checked="" type="checkbox"/> Yes	No	
From		338 feet to 100 feet		

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cool Degrees F Quality

Date started 3-10 -96
Date completed 3-15 -96

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	X Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
300+	245		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. 14170
NV Driller's Lic (on site) 1511
Signed *[Signature]*
By driller performing actual drilling on site or contractor
Date 3-16-96