

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31998

1. OWNER James Wisdom ADDRESS AT WELL LOCATION 978 Bench Rd
 MAILING ADDRESS 705 E. Stillwater #1 Fallen, NV 89406
 2. LOCATION SW 1/4 SW 1/4 Sec 7 T. 19 N. R. 27 E Churchill County
 PERMIT NO. 007-111-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	4	4
Clay & Silt		4	40	36
Clay		40	60	20
Course Sand		60	63	3
Clay & Silt		63	68	5
Fine Sand		68	90	22
Brown Clay		90	100	10
Clay & Sand		100	110	10
Sand & Gravel	x	110	122	12
Clay		122		

8. WELL CONSTRUCTION
 Depth Drilled 122 Feet Depth Cased 122 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 52 Feet
6 Inches 0 Feet 112 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	15.77	188	0	122

 Perforations:
 Type perforation machined
 Size perforation 1/8 x 3
 From 114 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 52' (0-52') Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet
 9. WATER LEVEL
 Static water level 42' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 19 Dec 1996
 Date completed 23 Dec 1996

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>3'</u>	<u>8</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon Cannon Contractor
 Address 4555 Hurstow Contractor
Silver Springs, NV 89409
 Nevada contractor's license number 23317
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1453
 Signed Vernon Cannon Jr.
 By driller performing actual drilling on site or contractor
 Date 23 Dec 96