

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 63451  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34382

1. OWNER Neventures, Inc. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 41705 North Tenth Street 3600 Rice Road Fallon, NV 89406  
Palmdale, CA 93551  
 2. LOCATION NE 1/4 SW 1/4 Sec. 22 T 19N N/S R 28E E Churchill County  
 PERMIT NO. 52101 Issued by Water Resources Parcel No. 008-211-26 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	18	8
Brown Sand		18	35	17
Gray Silt		35	42	7
Gray Sand		42	65	23
Brown Clay		65	70	5
Brown Sand		70	100	30
Gray Sand		100	150	50
Brown Clay		150	155	5
Brown Sand	X	155	170	15

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 14 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 170  
16 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.4	.250	0	170

Perforations:  
 Type perforation mill-cut  
 Size perforation 1/8  
 From 156 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 170 feet

9. WATER LEVEL  
 Static water level 19.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed Wayne P... ..  
 By driller performing actual drilling on-site or contractor  
 Date 8-22-96

Date started 8/16/96, 19  
 Date completed 8/17/96, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>300</u>		<u>1 hr.</u>

RECEIVED  
 20 JUN 23 PM 2:01  
 WATER RESOURCES DIVISION OFFICE