WHITE—DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63495
Permit No.
Basin

NOTICE OF INTENT NO. 16625

1. OWNER Gene, Larry, Elaine Goins
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec. 17 T 20-S N/S R 53 E Nye County
PERMIT NO. APN 36-262-24 (Issued by Water Resources) | 61 Unit E (Parcel No.) | Cal-Vegas Acres (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	16	12
Dark Brown Clay		16	40	24
Light Colored Clay	x	40	102	62
Hard Formation		102	112	10
Brown Clay	x	112	140	28

DCNR/DWR Received FEB 21 1996 LAS VEGAS OFFICE

Date started February 7, 1996
Date completed February 9, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [x] Pumped [ ] Poured
Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [x] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date February 12, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627