DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63501
Permit No.
Basin

1. OWNER Carey Harris ADDRESS

2. LOCATION N.W. ¼ S.E. ¼ Sec. 17 T. 20 N/S R. 53 E. Nye County
PERMIT NO. Domestic

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☒ Irrigation ☐ Test ☐	Cable ☐ Rotary ☒
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2'	2'
Dry Hard Clay		2'	4'	2'
White Loose Clay		4'	14'	10'
Bentonite		14'	22'	8'
Soft Clay	x	22'	32'	10'
Caliche		32'	34'	2'
Sandy Clay		34'	52'	18'
Clay & Caliche	x	52'	72'	20'
Tight Clay		72'	78'	6'
Sandy Clay		78'	99'	21'
Bentonite		99'	105'	6'
Caliche		105'	106'	1'
Soft Clay	x	106'	126'	20'
Sandy Clay		126'	156'	30'
Caliche		156'	158'	2'
Soft Clay	x	158'	169'	11'
Clay & Caliche		169'	170'	1
Caliche Hard		170'	178'	8'
Sandy Clay		178'	185'	7'
Sand	x	185'	186'	1'
Soft Sandy Clay	x	186'	201'	15'
Caliche		201'	205'	4'
Tight Clay		205'	209'	4'
Bentonite		209'	220'	11
Sandy Clay		220'	238'	18'
Soft Clay		238'	246'	8
Bentonite		246'	250	4'

Date started 8-1, 19 75
Date completed 8-4, 19 75

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
SEP 17 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST

G.P.M. 28 Draw down 11 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12 ¼ inches Total depth 250 feet
Casing record
Weight per foot 12.75 Thickness 10 Gauge

Diameter	From	To
8 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation Torch Cut
Size perforation ¼" x 12" 3 Rounds
From 160 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 28' Feet below land surface 28
Flow G.P.M.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Floyd Pump & Drilling
Address P.O. Box 328 Pahrump Nev.
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 8-18-75

USE ADDITIONAL SHEETS IF NECESSARY

5471