

WELL DRILLER'S REPORT

Please complete this form in its entirety

Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 9103

PRINT OR TYPE ONLY

1. OWNER Ronnie Murphy ( Jr. ) ADDRESS AT WELL LOCATION Horn  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NE 1/4 Sec. 17 T 20s N/S R. 53 E Nye County  
 PERMIT NO. N/A 36-282-13 Cal-Vegas Unit F Lot 209  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	6'	6'
caliche		6'	7'	1'
clay		7'	25'	18'
caliche		25'	28'	3'
clay		28'	41'	13'
caliche		41'	43'	2'
clay		43'	54'	11'
caliche		54'	57'	3'
clay		57'	73'	16'
caliche		73'	75'	2'
clay		75'	82'	7'
caliche	WB	82'	84'	2'
clay		84'	93'	9'
caliche	WB	93'	95'	2'
clay		95'	106'	11'
caliche	WB	106'	110'	4'
clay		110'	120'	10'
caliche	WB	120'	123'	3'
clay		123'	128'	5'
caliche	WB	128'	133'	5'
clay		133'	137'	4'
caliche	WB	137'	140'	3'

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8  
 Weight per foot 16.94 Thickness .188  

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140' feet to 50' feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8 x 3"  
 From 140' feet to 120' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-12, 1991  
 Date completed 3-15, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
RECEIVED			
MAR 18 1991			

9. WATER LEVEL  
 Static water level 57 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
Contractor  
 Address HCR 65 Box 80358 Pahrump Nv. 89041  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donna Brown  
By driller performing actual drilling on site or contractor  
 Date 3-15-91

Div. of Water Resources  
 Branch Office - Las Vegas  
 BAYLER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours