WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63615
Permit No.
Basin 162

NOTICE OF INTENT NO. 14623

1. OWNER William Starr
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2950 W. Charleston Park

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 36-213-24 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	16	9
Calichie		16	19	3
Clay		19	27	8
Calichie		27	29	2
Clay		29	40	11
Calichie		40	42	2
Clay		42	53	11
Calichie	WB	53	56	3
Clay		56	68	12
Calichie	WB	68	70	2
Clay		70	83	13
Calichie	WB	83	85	2
Clay		85	91	6
Calichie	WB	91	94	3
Clay		94	109	15
Calichie	WB	109	112	3
Clay		112	118	6
Calichie	WB	118	121	3
Clay		121	132	11
Calichie	WB	132	134	2
Clay		134	140	6

RECEIVED
MAY 16 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 21, 1995
Date completed April 27, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 5-3-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627