

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8780

PRINT OR TYPE ONLY

1. OWNER Raymond V. Mielzynski ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SW 1/4 Sec 19 T 20S N/S R 53 E NYE County \_\_\_\_\_  
 PERMIT NO. n/a 43-456-03 none  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	19'	19'
caliche		19'	22'	3'
clay		22'	32'	10'
caliche		32'	34'	2'
clay		34'	42'	8'
caliche		42'	44'	2'
clay		44'	57'	13'
caliche	WB	57'	59'	2'
clay		59'	63'	4'
caliche	WB	63'	65'	2'
clay		65'	70'	5'
caliche	WB	70'	73'	3'
clay		73'	80'	7'
caliche	WB	80'	82'	2'
clay		82'	90'	8'
caliche	WB	90'	92'	2'
clay		92'	98'	6'
caliche	WB	98'	101'	3'
clay		101'	112'	11'
caliche	WB	112'	114'	2'
clay		114'	121'	7'
caliche	WB	121'	123'	2'
clay		123'	131'	8'
caliche	WB	131'	133'	2'
clay		133'	140'	7'

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8"  
 Weight per foot 16.94 Thickness 1.88  

Diameter	From	To
<u>8 5/8"</u> inches	<u>0</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-24, 1990  
 Date completed 11-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING  
Contractor  
 Address HCR 65 box 80358 Pahrump, Nv u89041  
Contractor  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1426  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1573  
 Division of Water Resources, the on-site driller  
 Signed Raymond Brown  
By driller performing actual drilling on site or contractor  
 Date 11-19-90

RECEIVED

NOV 21 1990

BAILER Div of Water Resources  
Branch Office - Las Vegas, NV  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours