



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 3399

PRINT OR TYPE ONLY

OWNER TOM HEYN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SW 1/4 SE 1/4 Sec 20 T. 20S N/S R. 53 E NVE County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name LDT 4 BLOCK 5 UNIT 2 CALVADA

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	58	58
CALICHE		58	61	3
CLAY		61	75	14
CLAY	W.B.	75	81	6
CLAY		81	101	20
CLAY	W.B.	101	111	10
CLAY		111	126	15
CLAY	W.B.	126	135	9
CLAY		135	140	5

8. WELL CONSTRUCTION
 Diameter hole 12 1/2 inches Total depth 140 feet
 Casing record 8 5/8 00 140'
 Weight per foot 14.11 Thickness .156
 Diameter 8 5/8 inches From 0 feet To 140 feet
 Surface seal: Yes No Type CONCRETE
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 3/8 BY 3/4 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED
 SEP 13 1989
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 5.3 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL ° F. Quality _____

Date started 7-8, 1989
 Date completed 7-9, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S+H DRILLING Contractor
 Address HCR BOX 70906 Pahrump NV. Contractor
 Nevada contractor's license number 22059
 Nevada contractor's drillers number 1426
 Nevada driller's license number 1573 Actual Driller
 Signed Dennis Brown Contractor
 Date 8-9-89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours