WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 63663
Permit No.
Basin 162

1. OWNER D + W Construction ADDRESS
8-13 Block 22 Lot 10
2. LOCATION NE ¼ SE ¼ Sec. 21 T. 20 N/S R. 53 E. Nye County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
br. clay, white, tan clay				
green clay, cali stks		0	15	15
tan, lt. green clay				
cali stks.		15	30	15
lt. yellow clay, white &				
tan clay, cali stks.		30	45	15
white clay, tr. yellow				
clay, tan clay		45	60	15
white, tan clay, cali stks.		60	75	15
white, tan clay				
cali stks., gray clay		75	90	15
white, tan, gray clay		90	102	12
hard pan		102	104	2
tan br. + tr. of white clay				
tr. of gray clay, cali stks.		104	120	16
tan, br. tr. of white clay				
cali stks.		120	140	20

RECEIVED
DEC 16 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 8-26, 1980
Date completed 9-21, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 140 feet
Casing record 8 5/8
Weight per foot ..... Thickness .156 wall

Diameter	From	To
8 5/8 inches	140 feet	0 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal ..... feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 70 feet

Perforations:
Type perforation Torch
Size perforation 1/8" by 12"
From 140 feet to 78 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 29' Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address Pahrump, Nev.
Nevada contractor's license number 12344
Nevada driller's license number 588
Signed John Floyd
Date 10-8-80

USE ADDITIONAL SHEETS IF NECESSARY

5471