

OFFICE USE ONLY
 Log No. 63694
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 14619

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Joe Adamcik ADDRESS AT WELL LOCATION 1641 CALVADA PALMSPRING NV 89041
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NW 1/4 Sec 29 T. 205 N/S R. 53 E Nye County
 PERMIT NO. 40-251-03 Parcel No. _____ Subdivision Name Calvada Valley
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Caliche		3	7	4
Clay		7	38	31
Caliche		38	41	3
Clay		41	59	18
Caliche	WB	59	69	10
Clay		69	90	21
Caliche	WB	90	92	2
Clay		92	114	22
Caliche	WB	114	116	2
Clay		116	135	19
Caliche	WB	135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/2 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4-14 1995
 Date completed 4-19 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bail <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
			<u>MAY 08 1995</u>

Div. of Water Resources
 Branch Office - Las Vegas, NV

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Palm Springs NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas
 By driller performing actual drilling on site or contractor
 Date 4/25/95