WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63703
Permit No.
Basin

In Book

1. OWNER Phillip Phares ADDRESS Pahrump, NV 89041

2. LOCATION NW ¼ SW ¼ Sec. 29 T. 20-S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface		0	4	4
caliche formation		4	20	16
hard lime		20	25	5
white clay		25	48	23
brown clay	x	48	72	24
white clay		72	88	16
hard lime		88	93	5
brown clay	x	93	138	45

RECEIVED
JUN 13 1979
Div. of Water Resources
Ground Office — Las Vegas, Nev.

Date started 6-5, 1979
Date completed 6-6, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet 0 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 138 feet
Casing record 8" casing 138' deep
Weight per foot 13½ lbs Thickness 10ga

Diameter	From	To
8 inches	0 feet	138 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8" X 8"
From 60 feet to 138 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 29 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address 5231 Star Rt. Pahrump, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg MR
Date 6-9-79

USE ADDITIONAL SHEETS IF NECESSARY

5471