

OFFICE USE ONLY  
 Log No. 163718  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 14634

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dennis Paulson ADDRESS AT WELL LOCATION 3141 W. Winchester  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec. 32 T. 20S N/S R. 53 E Nye County  
 PERMIT NO. 40-512-32 Parcel No. Calvada Valley Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
caliche		2	4	2
Clay		4	8	4
caliche		8	24	16
Clay		24	55	31
caliche		55	58	3
Clay		58	78	20
caliche	WB	78	81	3
Clay		81	118	37
caliche	WB	118	122	4
Clay		122	137	15
caliche	WB	137	140	3

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory SAW CUT  
 Size perforation 1/2 x 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED  
 MAY 16 1995  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4/25, 1995  
 Date completed 4/28, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 5/4/95