


WELL DRILLERS REPORT

Please complete this form in its entirety



NOTICE OF INTENT NO. 4449

PRINT OR TYPE ONLY

1. OWNER LYLE SHECK ADDRESS AT WELL LOCATION 27 HALLS WAY PAHRUMP, NEV.
 MAILING ADDRESS GEN. DEL. PAHRUMP, NEV. 89041

2. LOCATION S.W. 1/4, N.E. 1/4 Sec 33 T. 20 N. R. 53 E. NYE County NYE
 PERMIT NO. _____ Parcel No. _____ Subdivision Name STARLIGHT OASIS ESTATES

3. TYPE OF WORK: New Well Recondition Deepen Other
 4. PROPOSED USE: Domestic Irrigation Municipal Industrial Test Stock
 5. TYPE WELL: Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
HARD BROWN CALECHE		1	6	5
BROWN CALECHE		6	37	31
BROWN CLAY		37	48	11
HARD BROWN CLAY		48	54	6
BROWN CLAY		54	71	17
BROWN CALECHE		71	93	22
HARD BROWN CLAY		93	112	19
BROWN CLAY		112	117	5
BENTONITE CLAY		117	134	17
HARD BROWN CLAY		134	140	6

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 140 feet
 Casing record 140 ft. 2 5/8" O.D.
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>2 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation TORCA CUT
 Size perforation 3/8" X 10"
 From 70 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 JAN 15 1988

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-3 1988
 Date completed 1-2 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 36 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ROW FLOYD PUMP DRILLING Contractor
 Address P.O. BOX 157 PAHRUMP, NEV. 89041 Contractor
 Nevada contractor's license number 7479-A
 Nevada contractor's drillers number 1424
 Nevada driller's license number 1427-STAN HARDIN Actual Driller
 Signed Row Floyd Contractor
 Date 1-12-88