

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29626

1. OWNER MARK IEE ADDRESS AT WELL LOCATION 175 Aurundell  
 MAILING ADDRESS 155 Aurundell In IN FALLON

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	18	18
Brown clay		18	20	2
Brown sand		20	25	5
Grey sands		25	40	15
Black silt clay		40	67	27
Grey sands		67	72	5
Grey clay		72	75	3
Brown sands		75	87	12

8. WELL CONSTRUCTION

Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 3/4</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>6 1/8</u> Inches	<u>50</u> Feet <u>87</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>1/8</u>	<u>1</u>	

Perforations:  
 Type perforation Machine cut  
 Size perforation 030

From 80 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 9' 4" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality ok

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Corp Contractor  
 Address 335 N Broadway Contractor  
FALLON  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
 Signed Jesus Narisumun  
 By driller performing actual drilling on site or contractor  
 Date 2-20-96

Date started 2-20 1996  
 Date completed 2-20 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>		<u>1 hr</u>