WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63753
Permit No.
Basin 101
34318
NOTICE OF INTENT NO.

1. OWNER DENNIS KEEGAN
MAILING ADDRESS 2655 CASEY ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
850 WETLAND VIEW

2. LOCATION NW 1/4 SE 1/4 Sec. 34 T ~~28~~ 19 N/S R ~~19~~ 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
008-652-34 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	20	20
BROWN CLAY		20	23	3
BROWN SAND		23	30	7
GREY SAND		30	45	15
GREY CLAY		45	50	5
GREY SAND		50	67	17
GREY CLAY		67	72	5
BROWN SAND	X	72	83	11

RECEIVED
96 AUG 12 AM 11:02
STATE ENGINEER'S OFFICE

Date started 7/27/96, 19__
Date completed 7/29/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 83 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4	Inches	0 Feet	50 Feet
6 1/8	Inches	50 Feet	83 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	1/8	+1	83

Perforations:
Type perforation MACHINE CUT
Size perforation .080
From 76 feet to 81 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 per Telcon
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11.25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality untested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-7-96