


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 63760
 Permit No. _____
 Basin 101
 34316
 NOTICE OF INTENT NO. 

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CAROLYN BOGAN ADDRESS AT WELL LOCATION 3038 BOTTOM ROAD
 MAILING ADDRESS 3038 BOTTOM ROAD
FALLON, NV 89406
 2. LOCATION NW 1/4 NW 1/4 Sec. 35 T 28 R 19 N/S R 18 E CHURCHILL County
 PERMIT NO. 10-541-27 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	18
BROWN CLAY		18	20	2
BROWN SAND		20	30	10
GREY SANDS		30	67	37
BROWN SILT		67	80	13
BLACK SILT CLAY		80	100	20
BROWN SILT		100	110	10
GREY SANDS \ CLAY		110	169	59
BROWN SAND	X	169	176	7


8. WELL CONSTRUCTION
 Depth Drilled 176 Feet Depth Cased 176 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/4 Inches 0 Feet 50 Feet
6 1/8 Inches 50 Feet 176 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	176

Perforations:
 Type perforation machine cut
 Size perforation .080
 From 169 feet to 174 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 17.75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Drilling Corp. Contractor
 Address P. O. BOX 888 Contractor
FALLON, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
 Signed 
 By driller performing actual drilling on-site or contractor
 Date 8-7-96

Date started 7/25/96 19__
 Date completed 7/25/96 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>1 hr.</u>

RECEIVED
 AUG 12 AM 11:02
 STATE ENGINEERING OFFICE