WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.179 and NAC 534.240

OFFICE USE ONLY
Log No. 63764
Permit No.
Basin 101

NOTICE OF INTENT NO. 31259

1. OWNER Nancy Bowman
MAILING ADDRESS P.O. Box 1858
Fallon, Nv 89406

ADDRESS AT WELL LOCATION
1111 Yucca Ln
Fallon, Nv 89406

2. LOCATION NW ¼ NW ¼ Sec. 8 T. 19 N/S R. 29 E/W Churchill County

PERMIT NO. 7-351-26
Issued by Water Resources — Parcel No. — Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	18	8
Brown Sand		18	21	3
Gray Silt		21	30	9
Gray Sand		30	55	25
Black Clay		55	60	5
Gray & Black Sand		60	80	20
Brownish Clay		80	85	5
Brownish Sand		85	95	10
Brown Clay		95	98	3
Brown Sand		98	103	5
Brown Clay		103	114	11
Brown Sand		114	120	6

Date started May 7, 19 96
Date completed May 8, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

Perforations:
Type perforation Mill Cut
Size perforation 1/8 inch
From 117 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality 120

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on site or contractor

Date 6-3-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627