

OFFICE USE ONLY
Log No. 63767
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33330

1. OWNER: Don Ymi Duncan
MAILING ADDRESS _____
ADDRESS AT WELL LOCATION: 1122 E. Ernest Drive Tallon, NV.
2. LOCATION: SW 1/4 SW 1/4 Sec 32 T 19 N/S R 29 E Churchill County
PERMIT NO. 10-492-07
Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other: Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>Sand Clay</u>		<u>18</u>	<u>32</u>	<u>14</u>
<u>Sand</u>		<u>32</u>	<u>40</u>	<u>8</u>
<u>Clay</u>		<u>40</u>	<u>61</u>	<u>21</u>
<u>Block Clay</u>		<u>61</u>	<u>103</u>	<u>42</u>
<u>Sand</u>		<u>103</u>	<u>119</u>	<u>16</u>
<u>Coarse Sand</u>		<u>119</u>	<u>130</u>	<u>11</u>

8. WELL CONSTRUCTION
Depth Drilled: 130 Feet Depth Cased: 131 Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 130 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>130</u>

Perforations:
Type perforation: Taper
Size perforation: 3/16 x 6 x 6 1/8
From 117 feet to 123 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal: 100
Placement Method: Pumped Drilled Poured
Gravel Packed: Yes No
From 100 feet to 130 feet

9. WATER LEVEL
Static water level: 6 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature: C °F Quality: Good

Date started: 6/18/94, 19____
Date completed: 6/20/94, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>8m</u>	<u>2 3/4</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Frank Drill Contractor
Address: PO 333 Contractor
333 N 89429
Nevada contractor's license number issued by the State Contractor's Board: 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1876
Signed: [Signature]
By driller performing actual drilling on site or contractor
Date: 6/25/94