WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63769
Permit No.
Basin

NOTICE OF INTENT NO. 30552

1. OWNER Duncan Philip
MAILING ADDRESS 1368 Bianchi Ln.
Fallon, Nv 89406

ADDRESS AT WELL LOCATION 1173 Ernst Dr.
Fallon, Nv 89406

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 19 N/S R. 29 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 10-494-09 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	28	28
Brown Clay		28	32	4
Gray Sand		32	39	7
Black Clay		39	45	6
Black Sand		45	51	6
Black Clay		51	59	8
Gray Sand		59	85	26
Gray Clay		85	90	5
Gray Sand		90	100	10
Brown Clay		100	110	10
Brown Sand		110	115	5
Brown Clay		115	135	20
Brown Sand	X	135	141	6

Date started January 18, 19 96
Date completed January 19, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 141 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From Feet	To Feet
XXX	10	0	141

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	141

Perforations:
Type perforation Mill Out
Size perforation 1/8 inch
From 138 feet to 141 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 141 feet

9. WATER LEVEL
Static water level 10'10" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv 89407

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-23-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627