WELL DRILLER'S COPY

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book

Log No. 63776
Permit No.
Basin

1. OWNER Calvada Test well ADDRESS

2. LOCATION NW ¼ SE ¼ Sec. 22 T. 20 N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☐ Irrigation ☐ Test ☒	Cable ☐ Rotary ☒
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0'	1'	1
Black clay		1'	9'	8'
Sandy clay		9'	22'	13'
Clay + caliche		22	30'	8'
Caverns clay		30'	50'	20'
Hard caliche		50'	55'	5'
Sandy clay		55'	65'	10'
Bentonite		65	95'	30'
Caving clay		95'	150'	55'
Soft grey clay		150'	165'	15'
Bentonite		165'	170'	5'
Clay + caliche stk.		170'	195'	25'
Soft white clay		195'	200'	5'

RECEIVED
OCT 29 1981
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 10-25-, 19 79
Date completed 10-15-, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 15" inches Total depth 200 feet
Casing record
Weight per foot Thickness

Diameter	From	To
10 3/4" inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" x 12" 3 Rounds
From 10 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 22 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne L. Floyd
Address P.O. Box 321
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 10-15-81

USE ADDITIONAL SHEETS IF NECESSARY

0-627