

OFFICE USE-ONLY  
 Log No. 63777  
 Permit No. \_\_\_\_\_  
 Basin. \_\_\_\_\_  
 NOTICE OF INTENT NO. N/A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lander County Sewer and Water Dist. #2 ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 144 Austin Nevada 89310

2. LOCATION S.E. 1/4 S.E. 1/4 Sec. 30 T. 19 S. R. 44 E. Lander County \_\_\_\_\_  
 PERMIT NO. 20158 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Horizontal  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite Cobbles	—	0	180	180
Granite cobbles, sandstone	20gpm	180	180	20
Granite Cobbles, sandstone	20gpm	180	260	80
Granite Cobbles sandstone, clay	40gpm	260	265	5
Granite Cobbles sandstone, clay	40gpm	265	345	80
Granite cobbles, sandstone	60gpm	345	355	10
Granite Cobbles, sandstone and clay	60gpm	355	380	25

Back of Hole at 13.5' Higher than surface of hole.  
 4" (Horizontal)  
 Incline 4" to 04-20-96  
 Hypochlorinated for 1.5 hours

8. WELL CONSTRUCTION  
 Depth Drilled 380 Feet Depth Cased 390 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 7.5 Feet  
4.75 Inches 75 Feet 380 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/2</u>	<u>0.69</u>	<u>.200</u>	<u>0</u>	<u>380</u>

Perforations:  
 Type perforation Slotted  
 Size perforation 0.016  
 From 80 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 7.5 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 42 °F Quality Good

Date started April 16 19 96  
 Date completed April 20 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>23</u>		<u>24</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jensen Drilling Company Contractor  
 Address 1775 Henderson Ave Eugene Oregon 97403 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 41572  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 3096  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date April 22 1996